

	- Certificate for pyrotechnics/fireworks,
Insurance	

Event Set – Up / Planning Checklist:

Public Assembly Event Self-Check Form Fire and Life Safety

Fire - Police - Rescue 911

RUPD Non-emergency (540) 831-5500 EHS Fire Safety – (540) 831-7792 or 7791

DATE: TIME: LOCATION:	
EVENT: PERSON DOING CHECK:	
Exit announcement read, displayed or posted? YesNo (If "no", arrange to provide the required announcement.)	
Exit doors clear and unobstructed (on both sides)? Yes No (If "no", remove the obstructions.)	
Exit paths clear and unobstructed all the way to outside? Yes No (If "no", remove the obstructions.)	
Wires taped down or otherwise secured? Yes No n/a (If "no", tape down or otherwise cover the wires.)	
Aisles clear and unobstructed? Yes No (If "no", remove the obstructions.)	
Exit lights on and unobstructed? Yes No (If "no", remove the obstructions.)	
Emergency lights unobstructed? Yes No (If "no", remove the obstructions.)	
Floor set-up approved? Yes No n/a (If "no", contact EHS immediately.)	
Fire protection equipment unobstructed? Yes No (If "no", remove the obstructions from: - Fire alarm pull stations; - Fire alarm horns, bells or speakers, and strobe lights; fire extinguishers.)	
Decorations non-flammable? Yes No n/a (If "no", remove the materials.)	
Use of open flames approved? Yes No n/a (If "no", extinguish and do not use.)	
Use of pyrotechnics approved? Yes No (If "no" - contact EHS immediately)	
Crowd managers in place?Yes No (If "no", contact EHS.) - 1 crowd manager for every 250 occupants	
Tents (< 125 square feet) are properly used? Yes No n/a - Tents should be properly erected and secured - All tent anchors and structural supports must be properly secured - Tents should be placed a minimum of 20 feet away from the buildings and structures - Tents should not be place under or close to foliage - Tents should not block any means of egress from other structures, sidewalks or emergency fire lanes	
 Tents should not block any means of egress from other structures, sidewarks of emergency fire falles A minimum of 20 feet distance should be maintained between any cooking activity / open flames and the tent 	

At least one multi-purpose (ABC) extinguisher (with minimum 4A rating) should be provided in the vicinity

Tents (over 125 square feet) have proper certification and permits if required? __ Yes __ No __ n/a

- Contact EHS Fire Safety for fire inspection prior to occupancy

- Flame retardant certification required at site

- Structural integrity

Emergency Medical Services in place? __ Yes __ No__n/a (If "no", contact the RU Rescue.)

Post-event check completed? __ Yes __ No (If "no", perform post event check.)

- Smoking materials safely extinguished (where smoking is allowed)

- Approved open flames safely extinguished

- Unnecessary electrical equipment turned off

- No obvious hazards